



Certificate of Compliance

Certificate: 2665124

Master Contract: 259363

Project: 70150964

Date Issued: August 2, 2017

Issued to: Solectria Renewables,LLC.
360 Marrimack St.Bldg 9,
Lawrence,
MA,01843,
USA

Attention: Mr. James Worden

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: *Michael Tong*
Michael Tong

PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment
CLASS 5311 89 - POWER SUPPLIES - Distributed Generation - Power Systems Equipment
- Certified to U.S. Standards

Transformerless Utility Interactive Inverter, Models PVI 23TL-480 and PVI 28TL-480, permanently connected.

Transformerless Grid Support Utility Interactive Inverter, Model PVI 36TL-480, permanently connected.

Note:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.



Certificate: 2665124
Project: 70150964

Master Contract: 259363
Date Issued: August 2, 2017

APPLICABLE REQUIREMENTS

For Models PVI 23TL-480 and PVI 28TL-480.

CSA C22.2 No. 107.1-01 - General Use Power Supplies
*UL 1741 - Inverters, Converters, Controllers and Interconnection System
Equipment for Use With Distributed Energy Resources (January 28, 2010)
CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue
Number 1, March 11, 2013)
UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue
Number 2, January 14, 2013)

*Note: Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of IEEE 1547-2003 (R2008) and IEEE 1547.1-2005(R2011).

For Model PVI 36TL-480.

CSA C22.2 No. 107.1-01 - General Use Power Supplies
*UL 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With
Distributed Energy Resources (Second Edition, Revision September 7, 2016)
CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue
Number 1, March 11, 2013)
UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue
Number 2, January 14, 2013)

*Note: Conformity to UL 1741 (Second Edition, Revision September 7, 2016) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547.1-2005(R2011), California Rule 21 and Supplement SA.



Supplement to Certificate of Compliance

Certificate: 2665124

Master Contract: 259363

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70150964	August 2, 2017	Update model PVI 36TL-480 to add grid support functions.
70036193	Jun 12, 2015	Multiple Listing. Model No. Listee Model No
		2645180 CPS SCA36KTL-DO/US PVI 36TL-480
2665124	Sep 26,2013	Multiple Listing.
		Original Report Model No. Listee Model No
		2645180 CPS SCA23KTL-DO/US-480 PVI 23TL-480
		2645180 CPS SCA28KTL-DO/US-480 PVI 28TL-480