



Certificate of Compliance

Certificate: 70219787

Master Contract: 259363

Project: 70219787

Date Issued: 2019-03-19

Issued to: Solectria Renewables, LLC
360 Merrimack St Bldg 9 Flr 2
Lawrence, MA 01843
USA
Attention: Jihua Ma

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yang (Jason) Lei
Yang (Jason) Lei

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Transformerless Grid Support Utility Interactive Inverter.

Models PVI 50TL-480 and PVI 60TL-480.



Certificate: 70219787
Project: 70219787

Master Contract: 259363
Date Issued: 2019-03-19

APPLICABLE REQUIREMENTS

CSA C22.2 No. 107.1-01 - General Use Power Supplies

*UL 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision September 7, 2016)

CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)

UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)

*Note: Conformity to UL 1741 (Second Edition, Revision September 7, 2016) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011), IEEE 1547.1a-2015, California Rule 21 and Supplement SA.